

# GROUND

ENGINEERING CONSULTANTS

## GRADATION PROPERTIES

Date: October 13, 2009

Job Number: 09-1019

Copies to:

### Sample Information

Allied Job Number: A-92909

Sample Number: 2549

Sample Location: 4082

Aggregate Identification: Recycled Asphalt

Date Sampled: 9/29/2009

### Gradation Analysis (ASTM C136)

Sieve Size (opening)	Passing (%)
1"	100
3/4"	100
1/2"	85
3/8"	71
#4	49
#8	33
#16	21
#30	11
#50	4
#100	1
#200	0.3

% AC By Ignition Oven

4.98\*